



Rhode Island

Airport Corporation

March 6, 2023

ADDENDUM NO. 1
Invitation for Bids No. 33602
SFZ Tie-Down Apron Reconstruction
North Central State Airport

Prospective Bidders and all concerned are hereby notified of the following changes in the Invitation for Bids (IFB) No. 33602. These changes shall be incorporated in and shall become an integral part of the contract documents.

QUESTIONS AND ANSWERS

1. In the specifications page 01571-4 sections 3.2 Vehicles and Mobile Equipment, it discusses escort vehicles. In the event an escort is required is this a service supplied by the facility, or is this a service we need to pay for and what is the payment requirements if this is the case?

Escort from Gate 2 to the work area will be provided by RIAC.

2. In specifications page P-4030-7 f 20 Material Transfer Vehicle, can you please confirm if an MTV will be required for this project?

An MTV is not required for this project. See Addenda Item 3 below.

3. In the project specifications page G-001-2 of 8, section 001-10.1 RADIO CONTROL it specifies, requirements for a control vehicle, field office, and superintendent's vehicle, all to be equipped with a two ray radio. There is an additional section requiring a full-time radio operator in a designated control vehicle with a rotating amber light to monitor the radios at all working hours. Due to the project not taking place on an active runway or taxiway can you please specify if all or which specific requirements are needed for this project?

A contractor radio control vehicle is not required for this project. See Addenda Item 4 below.

4. In reviewing the plans and specifications for the Tie-Down Apron project I have a question on the low profile barricades. I have attached screen snips to the bottom of this email. Thank you. Sheet G1.4 LOW-PROFILEBARRICADE Note 2 specifies barricades shall be water filled. Specifications section 01571 2.6 "Plastic Protective Barriers (Water Filled) - Not Used" specifies water filled barriers are not used. Is the project intent to use the water filled barricades as specified in the drawings or is there an alternate barricade we should use?

The Barricades shown on G1.4 shall be used. See addenda Item 1 and 2 below.

5. How to Tie downs be installed?

Means and methods are the responsibility of the contractor, the end result matching the detail on drawing GD2.1.

6. Field Office requirements: can we get space in the building?

Contact Flight Level Aviation with rental questions.

REVISIONS TO PROJECT SPECIFICATIONS

7. In SECTION 01571 – MAINTENANCE OF AIRCRAFT OPERATIONS AREA TRAFFIC, Paragraph 2.5, DELETE text of paragraph and REPLACE WITH:

"Not Used"

8. In SECTION 01571 – MAINTENANCE OF AIRCRAFT OPERATIONS AREA TRAFFIC, Paragraph 2.6, DELETE text of paragraph and REPLACE WITH:

"Furnish, install and maintain temporary plastic barricades in the locations shown on the Drawings, in accordance with the approved layout for each construction area and as directed by the Engineer.

Plastic barricades, meeting the following requirements, shall only be used when specifically shown on the Drawings or ordered by the Engineer.

A. Each barricade is marked with diagonal, alternating orange and white reflective grade tape 6" wide. Also each will have two 3-way approved solar red lights meeting state dot standards.

B. Barricades shall be filled with water only.

C. Designed to FAA AC 150/5340-1 & 150/5370-2 (current edition) specifications and performance standards.

D. Made of durable polyethylene plastic.

E. Barricades shall be interlocked. Contractor to verify sufficient number of barricades.

F. Contractor to provide barricades. The contractor shall be responsible for setup, maintenance, and light operations, including providing batteries if needed. At the end of the project, barricades shall remain property of the contractor.”

REVISIONS TO TECHNICAL SPECIFICATIONS

9. In SECTION P-403 – ASPHALT MIX PAVEMENT BASE COURSE, Paragraph 403-4.4.1, DELETE text of paragraph and REPLACE WITH:

“A material transfer vehicle is not required.”

10. In SECTION G-001 – SUMMARY OF WORK AND SPECIAL WORK REQUIREMENTS, Paragraph 001-10.1, DELETE text of paragraph and REPLACE WITH:

“Not Used”

RIAC would like to remind all prospective bidders/offerors that additional Addendums may be issued by RIAC until the deadline for bid submissions. As such, RIAC encourages prospective bidders/offerors to visit www.flyri.com/riac/procurement on a frequent basis.

####END OF ADDENDUM####